

LUBBOCK COUNTY LAW ENFORCEMENT CENTER
GENERATOR REPLACEMENT – COUNTY ITB NO. 190603

AGNEW ASSOCIATES, INC.
TEXAS REGISTERED ENGINEERING FIRM F-1005
PROJECT NUMBER 1219026



JULY 5, 2019

The seal appearing on this document was authorized by David D. Laughlin, PE 70901, on July 5, 2019. Alteration of a sealed document without proper notification to the responsible engineer is an offense under the Texas Engineering Practice Act.

NOTICE TO ALL BIDDERS:

The following shall be incorporated in and become a part of the original Drawings and Specifications of the above identified project. Please acknowledge receipt of this Addendum by noting it on your Proposal.

GENERAL ITEMS:

- Item 1. The sign-in sheet for the Pre-Bid Meeting is attached.
- Item 2. Temporary Emergency Power: The contractor is advised that no downtime of the separately derived power source shall exceed 1 hour in duration. As such the contractor shall include all material, labor, tools and charges associated with providing a minimum 80 KW portable generator on site for use during the project to eliminate all potential down time for the existing loads in the event of normal power failure to no more than 1 hour. The generator must be on site with all required cabling, fuel, safety provisions, etc. and ready to provide temporary power in the event of a failure of utility service power before the existing generator may be taken out of service. The temporary generator shall remain onsite and available as the alternate power source until such time as the new generator is fully installed, started by a factory representative and load tested as specified. Failure to meet the requirements of this provision shall result in the assessment of liquidated damages in the amount of \$1000 per hour until such time as this requirement is fulfilled.

SPECIFICATIONS:

- Item 1. In the Specifications, Section 16620, replace paragraph 2.01.A with the following:
 - A. General: The standby engine generator shall be of Caterpillar, Cummins, or Kohler manufacture. No Exceptions.

End of Addendum #1



LUBBOCK COUNTY LAW ENFORCEMENT CENTER
GENERATOR REPLACEMENT
JULY 2, 2019

PREBID CONFERENCE

NAME	COMPANY	PHONE NO.	EMAIL
David Laughlin, PE	Agnew Associates	806-799-0753	dlaughlin@ agnewassociates.com
Russell Brown	Acme Electric	806-745-7720	russell@acmeelect.com
Ryan Brown	Acme Electric	806-745-7720	ryanbrown@acmeelect.com
RANDY L. DAYTON	C.G. ELECTRIC	(806) 745-1345	cceclubbock@gmail.com
PAUL TARVER	LUBBOCK CO	548-6438	PTARVER@CO.LUBBOCK.TX
Dave Brannon	Lubbock Co	548-6452	dbrannon@co.---
L.W. Howard	L. Howard Const	832-5618	lhowardconst@v.lubbock.tx.us
Kevin Harris	SPS Electric	793-5471	kevin@sps-electric.net
Connie Stamps	L. Howard Const	806-832-5618	
Lisa Pevey	L. Howard Const.	806-832-5618	lh-estimating@windstream.net
Philip Drake	Phil Drake	806-500-1898	p.drake@SSSS.com
Natalie Harvill	Lubbock Co	775-1003	nharvill@co.lubbock.tx.us
Mande Reeves	Lubbock Co	775-1017	mreeves@co.lubbock.tx.us